

## PENNSVILLE TWSP. WATER DEPART.

PENNSVILLE, NJ | PWSID: NJ1708001 | Population served: 13,500  
Based on EPA UCMR 5 testing data (2023-2025) | Report generated April 8, 2026



### PFOA exceeds the federal limit at 2.84x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

### Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFOA	11.3	4.0	2.84	<b>EXCEEDS</b>
PFPeA	24.0	-	-	No federal limit
PFHxA	18.8	-	-	No federal limit
PFBA	12.7	-	-	No federal limit
PFHpA	12.1	-	-	No federal limit

### What This Means

This water system serves 13,500 residents in PENNSVILLE. EPA testing detected 29 PFAS compounds, 1 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

### What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans