

## Veolia Water NY

WEST NYACK, NY | PWSID: NY4303673 | Population served: 270,000  
Based on EPA UCMR 5 testing data (2023-2025) | Report generated April 8, 2026



### PFOA exceeds the federal limit at 2.02x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

### Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFOA	8.1	4.0	2.02	<b>EXCEEDS</b>
PFOS	5.6	4.0	1.39	<b>EXCEEDS</b>
PFHxS	6.2	10.0	0.62	Below limit
PFNA	5.0	10.0	0.50	Below limit
6:2FTS	9.7	-	-	No federal limit
PFBA	5.6	-	-	No federal limit
PFPeA	5.3	-	-	No federal limit
PFHxA	4.6	-	-	No federal limit
PFBS	4.5	-	-	No federal limit
PFHpA	3.8	-	-	No federal limit

### What This Means

This water system serves 270,000 residents in WEST NYACK. EPA testing detected 29 PFAS compounds, 2 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

### What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans