Water Quality Report Card

CheckYourWater.org

YESHIVA FARM SETTLEMENT

MT. KISCO, NY | PWSID: NY5903150 | Population served: 300

Based on EPA UCMR 5 testing data (2023-2025) | Report generated November 25, 2026

F

PFOS severely exceeds the federal limit at 23.61x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFOS	94.5	4.0	23.61	**EXCEEDS**
PFOA	24.9	4.0	6.24	**EXCEEDS**
PFHxS	47.2	10.0	4.72	**EXCEEDS**
PFNA	4.6	10.0	0.46	Below limit
PFPeA	96.6	-	-	No federal limit
PFHxA	66.3	-	-	No federal limit
PFHpA	41.4	-	-	No federal limit
PFBA	27.6	-	-	No federal limit
PFPeS	6.4	-	-	No federal limit
PFBS	5.5	-	-	No federal limit

What This Means

This water system serves 300 residents in MT. KISCO. EPA testing detected 29 PFAS compounds, 3 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans

This report is provided for informational purposes. It is not a substitute for professional water quality analysis.