

## YESHIVA FARM SETTLEMENT

MT. KISCO, NY | PWSID: NY5903150 | Population served: 300

Based on EPA UCMR 5 testing data (2023-2025) | Report generated July 10, 2026



### PFOS severely exceeds the federal limit at 23.61x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

### Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFOS	94.5	4.0	23.61	<b>EXCEEDS</b>
PFOA	24.9	4.0	6.24	<b>EXCEEDS</b>
PFHxS	47.2	10.0	4.72	<b>EXCEEDS</b>
PFNA	4.6	10.0	0.46	Below limit
PFPeA	96.6	-	-	No federal limit
PFHxA	66.3	-	-	No federal limit
PFHpA	41.4	-	-	No federal limit
PFBA	27.6	-	-	No federal limit
PFPeS	6.4	-	-	No federal limit
PFBS	5.5	-	-	No federal limit

### What This Means

This water system serves 300 residents in MT. KISCO. EPA testing detected 29 PFAS compounds, 3 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

### What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans