

## PEQUENAKONCK ELEMENTARY SCHOOL

NORTH SALEM, NY | PWSID: NY5907717 | Population served: 700  
Based on EPA UCMR 5 testing data (2023-2025) | Report generated May 25, 2026



### PFOA severely exceeds the federal limit at 27.88x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

### Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFOA	111.5	4.0	27.88	<b>EXCEEDS</b>
PFNA	26.4	10.0	2.64	<b>EXCEEDS</b>
PFOS	10.0	4.0	2.50	<b>EXCEEDS</b>
PFHxA	160.4	-	-	No federal limit
PFPeA	134.4	-	-	No federal limit
PFBA	49.7	-	-	No federal limit
PFHpA	48.2	-	-	No federal limit
PFDA	3.8	-	-	No federal limit

### What This Means

This water system serves 700 residents in NORTH SALEM. EPA testing detected 29 PFAS compounds, 3 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

### What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans