

## WRIGHT-PATTERSON AFB AREA A PWS

VANDALIA, OH | PWSID: OH2903412 | Population served: 16,551

Based on EPA UCMR 5 testing data (2023-2025) | Report generated April 8, 2026



### PFOS exceeds the federal limit at 1.24x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

### Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFOS	5.0	4.0	1.24	<b>EXCEEDS</b>
PFHxS	9.3	10.0	0.93	Below limit
PFHxA	24.7	-	-	No federal limit
PFPeA	22.3	-	-	No federal limit
PFBA	8.1	-	-	No federal limit
PFBS	7.1	-	-	No federal limit
PFHpA	3.7	-	-	No federal limit

### What This Means

This water system serves 16,551 residents in VANDALIA. EPA testing detected 29 PFAS compounds, 1 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

### What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans