

EDMOND PWA - ARCADIA

EDMOND, OK | PWSID: OK1020723 | Population served: 79,408

Based on EPA UCMR 5 testing data (2023-2025) | Report generated May 25, 2026



PFOS exceeds the federal limit at 1.34x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFOS	5.4	4.0	1.34	EXCEEDS
PFHxS	3.9	10.0	0.39	Below limit
PFBA	6.0	-	-	No federal limit
PFHxA	5.1	-	-	No federal limit
PFBS	4.4	-	-	No federal limit
PFPeA	4.2	-	-	No federal limit

What This Means

This water system serves 79,408 residents in EDMOND. EPA testing detected 29 PFAS compounds, 1 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans