

## WAGONER CO. RWD #5

COWETA, OK | PWSID: OK1021528 | Population served: 4,251

Based on EPA UCMR 5 testing data (2023-2025) | Report generated April 8, 2026



### PFOS severely exceeds the federal limit at 5.09x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

### Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFOS	20.4	4.0	5.09	<b>EXCEEDS</b>
PFHxS	11.1	10.0	1.11	<b>EXCEEDS</b>
PFBA	7.9	-	-	No federal limit
PFHxA	6.3	-	-	No federal limit
PFPeA	5.1	-	-	No federal limit
PFBS	3.2	-	-	No federal limit

### What This Means

This water system serves 4,251 residents in COWETA. EPA testing detected 29 PFAS compounds, 2 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

### What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans