

## TINKER AFB BIO-ENV ENG

OKLAHOMA CITY, OK | PWSID: OK2005508 | Population served: 24,645

Based on EPA UCMR 5 testing data (2023-2025) | Report generated April 8, 2026



### PFHxS detected at 51% of the federal limit, approaching the threshold

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

### Findings

| Compound | Detected (ppt) | EPA Limit (ppt) | Ratio | Status      |
|----------|----------------|-----------------|-------|-------------|
| PFHxS    | 5.0            | 10.0            | 0.51  | Below limit |

### What This Means

This water system serves 24,645 residents in OKLAHOMA CITY. EPA testing detected 29 PFAS compounds, 0 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

### What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans