

## RUCH ELEMENTARY SD 549

MEDFORD, OR | PWSID: OR4191508 | Population served: 200

Based on EPA UCMR 5 testing data (2023-2025) | Report generated April 8, 2026



### PFHxS exceeds the federal limit at 3.06x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

### Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFHxS	30.6	10.0	3.06	<b>EXCEEDS</b>
PFOS	9.8	4.0	2.44	<b>EXCEEDS</b>
PFOA	9.3	4.0	2.31	<b>EXCEEDS</b>
PFHxA	13.8	-	-	No federal limit
PFBS	12.9	-	-	No federal limit
PFPeA	12.7	-	-	No federal limit
PFPeS	8.6	-	-	No federal limit
PFHpA	3.7	-	-	No federal limit

### What This Means

This water system serves 200 residents in MEDFORD. EPA testing detected 29 PFAS compounds, 3 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

### What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans