

## QUAKERTOWN BORO

QUAKERTOWN, PA | PWSID: PA1090082 | Population served: 12,800  
Based on EPA UCMR 5 testing data (2023-2025) | Report generated April 8, 2026



### PFNA exceeds the federal limit at 2.39x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

### Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFNA	23.9	10.0	2.39	<b>EXCEEDS</b>
PFOS	7.8	4.0	1.94	<b>EXCEEDS</b>
PFOA	6.0	4.0	1.50	<b>EXCEEDS</b>
PFHxS	3.0	10.0	0.30	Below limit
PFBA	5.9	-	-	No federal limit
PFPeA	5.0	-	-	No federal limit
PFBS	4.7	-	-	No federal limit
PFHxA	4.3	-	-	No federal limit

### What This Means

This water system serves 12,800 residents in QUAKERTOWN. EPA testing detected 29 PFAS compounds, 3 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

### What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans