

## AUDUBON WATER COMPANY

NORRISTOWN, PA | PWSID: PA1460055 | Population served: 8,200  
Based on EPA UCMR 5 testing data (2023-2025) | Report generated July 10, 2026



### PFOS severely exceeds the federal limit at 5.20x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

### Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFOS	20.8	4.0	5.20	<b>EXCEEDS</b>
PFOA	13.4	4.0	3.36	<b>EXCEEDS</b>
PFNA	6.1	10.0	0.61	Below limit
PFHxS	4.2	10.0	0.41	Below limit
PFPeA	8.1	-	-	No federal limit
PFHxA	7.3	-	-	No federal limit
PFBA	5.9	-	-	No federal limit
PFHpA	5.5	-	-	No federal limit
PFBS	4.1	-	-	No federal limit

### What This Means

This water system serves 8,200 residents in NORRISTOWN. EPA testing detected 29 PFAS compounds, 2 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

### What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans