

## ABBEVILLE CITY OF

ABBEVILLE, SC | PWSID: SC0110001 | Population served: 5,640  
Based on EPA UCMR 5 testing data (2023-2025) | Report generated April 8, 2026



### HFPO-DA severely exceeds the federal limit at 5.18x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

### Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
HFPO-DA	51.8	10.0	5.18	<b>EXCEEDS</b>
PFBS	6.2	-	-	No federal limit
PFPeA	4.3	-	-	No federal limit
PFHxA	3.8	-	-	No federal limit

### What This Means

This water system serves 5,640 residents in ABBEVILLE. EPA testing detected 29 PFAS compounds, 1 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

### What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans