

## GRASSY POND WATER CO (1120002)

GAFFNEY, SC | PWSID: SC1120002 | Population served: 9,458

Based on EPA UCMR 5 testing data (2023-2025) | Report generated April 8, 2026



### PFOS exceeds the federal limit at 3.89x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

### Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFOS	15.6	4.0	3.89	<b>EXCEEDS</b>
PFOA	12.7	4.0	3.16	<b>EXCEEDS</b>
PFHxS	4.8	10.0	0.48	Below limit
PFHpA	4.5	-	-	No federal limit
PFPeA	4.4	-	-	No federal limit
PFHxA	3.9	-	-	No federal limit
PFBS	3.2	-	-	No federal limit

### What This Means

This water system serves 9,458 residents in GAFFNEY. EPA testing detected 29 PFAS compounds, 2 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

### What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans