

## CONWAY CITY OF (SC2610008)

CONWAY, SC | PWSID: SC2610008 | Population served: 27,005

Based on EPA UCMR 5 testing data (2023-2025) | Report generated April 8, 2026



### PFOS exceeds the federal limit at 2.02x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

### Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFOS	8.1	4.0	2.02	<b>EXCEEDS</b>
PFOA	7.7	4.0	1.91	<b>EXCEEDS</b>
PFPeA	7.7	-	-	No federal limit
PFBA	5.9	-	-	No federal limit
PFHxA	5.0	-	-	No federal limit
PFHpA	3.4	-	-	No federal limit
PFBS	3.0	-	-	No federal limit

### What This Means

This water system serves 27,005 residents in CONWAY. EPA testing detected 29 PFAS compounds, 2 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

### What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans