

## LAURENS COUNTY W&S COMM (SC3020001)

LAURENS, SC | PWSID: SC3020001 | Population served: 36,314

Based on EPA UCMR 5 testing data (2023-2025) | Report generated May 25, 2026



### HFPO-DA exceeds the federal limit at 2.91x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

### Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
HFPO-DA	29.1	10.0	2.91	<b>EXCEEDS</b>
PFOS	7.1	4.0	1.76	<b>EXCEEDS</b>
PFOA	5.7	4.0	1.43	<b>EXCEEDS</b>
PFHxS	3.1	10.0	0.31	Below limit
PFPeA	8.6	-	-	No federal limit
PFBS	7.7	-	-	No federal limit
PFHxA	7.2	-	-	No federal limit
PFBA	7.2	-	-	No federal limit
PFHpA	3.3	-	-	No federal limit

### What This Means

This water system serves 36,314 residents in LAURENS. EPA testing detected 29 PFAS compounds, 3 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

### What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans