

## SALUDA CPW (4110001)

SALUDA, SC | PWSID: SC4110001 | Population served: 3,390

Based on EPA UCMR 5 testing data (2023-2025) | Report generated May 25, 2026



### HFPO-DA exceeds the federal limit at 2.90x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

### Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
HFPO-DA	29.0	10.0	2.90	<b>EXCEEDS</b>
PFOS	7.9	4.0	1.97	<b>EXCEEDS</b>
PFOA	4.9	4.0	1.22	<b>EXCEEDS</b>
PFPeA	7.9	-	-	No federal limit
PFHxA	5.0	-	-	No federal limit
PFBS	3.8	-	-	No federal limit

### What This Means

This water system serves 3,390 residents in SALUDA. EPA testing detected 29 PFAS compounds, 3 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

### What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans