

SAVANNAH VALLEY U. D.

GEORGETOWN, TN | PWSID: TN0000613 | Population served: 30,571
Based on EPA UCMR 5 testing data (2023-2025) | Report generated May 25, 2026



PFOA severely exceeds the federal limit at 8.00x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFOA	32.0	4.0	8.00	EXCEEDS
PFOS	16.5	4.0	4.13	EXCEEDS
PFHxS	4.5	10.0	0.45	Below limit
PFPeA	27.5	-	-	No federal limit
PFHxA	26.0	-	-	No federal limit
PFBS	20.5	-	-	No federal limit
PFHpA	12.5	-	-	No federal limit
PFBA	10.8	-	-	No federal limit

What This Means

This water system serves 30,571 residents in GEORGETOWN. EPA testing detected 29 PFAS compounds, 2 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans