

## SAVANNAH VALLEY U. D.

GEORGETOWN, TN | PWSID: TN0000613 | Population served: 30,571  
Based on EPA UCMR 5 testing data (2023-2025) | Report generated July 10, 2026



### PFOA severely exceeds the federal limit at 8.00x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

### Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFOA	32.0	4.0	8.00	<b>EXCEEDS</b>
PFOS	16.5	4.0	4.13	<b>EXCEEDS</b>
PFHxS	4.5	10.0	0.45	Below limit
PFPeA	27.5	-	-	No federal limit
PFHxA	26.0	-	-	No federal limit
PFBS	20.5	-	-	No federal limit
PFHpA	12.5	-	-	No federal limit
PFBA	10.8	-	-	No federal limit

### What This Means

This water system serves 30,571 residents in GEORGETOWN. EPA testing detected 29 PFAS compounds, 2 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

### What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans