

## FORT CAMPBELL WATER SYSTEM

FT. CAMPBELL, TN | PWSID: TN0000820 | Population served: 43,270  
Based on EPA UCMR 5 testing data (2023-2025) | Report generated May 25, 2026



### PFOS severely exceeds the federal limit at 6.19x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

### Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFOS	24.8	4.0	6.19	<b>EXCEEDS</b>
PFHxS	30.1	10.0	3.01	<b>EXCEEDS</b>
PFOA	5.8	4.0	1.44	<b>EXCEEDS</b>
PFHxA	7.2	-	-	No federal limit
PFPeA	6.0	-	-	No federal limit
PFBS	3.5	-	-	No federal limit
PFHpA	3.2	-	-	No federal limit

### What This Means

This water system serves 43,270 residents in FT. CAMPBELL. EPA testing detected 29 PFAS compounds, 3 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

### What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans