

## CITY OF COCKRELL HILL

DALLAS, TX | PWSID: TX0570038 | Population served: 3,820

Based on EPA UCMR 5 testing data (2023-2025) | Report generated May 25, 2026



### PFOA exceeds the federal limit at 1.27x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

### Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFOA	5.1	4.0	1.27	<b>EXCEEDS</b>
PFOS	4.1	4.0	1.02	<b>EXCEEDS</b>
PFHxS	3.6	10.0	0.36	Below limit
PFPeA	9.9	-	-	No federal limit
PFHxA	9.7	-	-	No federal limit
PFBA	8.1	-	-	No federal limit
PFBS	5.0	-	-	No federal limit
PFHpA	3.7	-	-	No federal limit

### What This Means

This water system serves 3,820 residents in DALLAS. EPA testing detected 29 PFAS compounds, 2 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

### What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans