

## CITY OF ABILENE

ABILENE, TX | PWSID: TX2210001 | Population served: 125,182  
Based on EPA UCMR 5 testing data (2023-2025) | Report generated July 10, 2026



### PFOS severely exceeds the federal limit at 6.13x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

### Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFOS	24.5	4.0	6.13	EXCEEDS
PFHxS	20.5	10.0	2.05	EXCEEDS
PFOA	6.7	4.0	1.68	EXCEEDS
PFHxA	18.3	-	-	No federal limit
PFPeA	17.2	-	-	No federal limit
PFBA	17.1	-	-	No federal limit
PFHpA	9.4	-	-	No federal limit
PFBS	6.6	-	-	No federal limit
PFPeS	4.4	-	-	No federal limit

### What This Means

This water system serves 125,182 residents in ABILENE. EPA testing detected 29 PFAS compounds, 3 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

### What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans