

## MANVILLE WSC

COUPLAND, TX | PWSID: TX2270033 | Population served: 39,648

Based on EPA UCMR 5 testing data (2023-2025) | Report generated May 25, 2026



### PFOS exceeds the federal limit at 1.63x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

### Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFOS	6.5	4.0	1.63	<b>EXCEEDS</b>
PFOA	5.9	4.0	1.48	<b>EXCEEDS</b>
PFNA	13.7	10.0	1.37	<b>EXCEEDS</b>
PFHxS	4.9	10.0	0.49	Below limit
PFBA	6.0	-	-	No federal limit
PFBS	5.9	-	-	No federal limit
PFPeA	5.3	-	-	No federal limit
PFHxA	5.0	-	-	No federal limit
PFHpA	4.3	-	-	No federal limit
PFUnA	2.7	-	-	No federal limit

### What This Means

This water system serves 39,648 residents in COUPLAND. EPA testing detected 29 PFAS compounds, 3 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

### What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans