# Water Quality Report Card

CheckYourWater.org

## DANVILLE, CITY OF

DANVILLE, VA | PWSID: VA5590100 | Population served: 43,055

Based on EPA UCMR 5 testing data (2023-2025) | Report generated November 25, 2026

**D**

### PFOA exceeds the federal limit at 2.27x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

## Findings

| Compound | Detected (ppt) | EPA Limit (ppt) | Ratio | Status |
|---|---|---|---|---|
| PFOA | 9.1 | 4.0 | 2.27 | **EXCEEDS** |

## What This Means

This water system serves 43,055 residents in DANVILLE. EPA testing detected 29 PFAS compounds, 1 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

## What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans



This report is provided for informational purposes. It is not a substitute for professional water quality analysis.