

## BEALETON REGIONAL

WARRENTON, VA | PWSID: VA6061129 | Population served: 4,250  
Based on EPA UCMR 5 testing data (2023-2025) | Report generated May 25, 2026



### PFOA severely exceeds the federal limit at 6.77x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

### Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFOA	27.1	4.0	6.77	<b>EXCEEDS</b>
PFOS	17.0	4.0	4.25	<b>EXCEEDS</b>
PFHxS	4.8	10.0	0.48	Below limit
PFNA	4.8	10.0	0.48	Below limit
PFBS	11.5	-	-	No federal limit
PFPeA	9.6	-	-	No federal limit
PFHpA	9.1	-	-	No federal limit
PFHxA	8.5	-	-	No federal limit
PFBA	7.4	-	-	No federal limit

### What This Means

This water system serves 4,250 residents in WARRENTON. EPA testing detected 29 PFAS compounds, 2 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

### What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans