

## KENNEWICK CITY OF

Kennewick, WA | PWSID: WA5338100 | Population served: 114,468  
Based on EPA UCMR 5 testing data (2023-2025) | Report generated May 25, 2026



### PFOS exceeds the federal limit at 2.49x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

### Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFOS	10.0	4.0	2.49	<b>EXCEEDS</b>
PFOA	4.5	4.0	1.11	<b>EXCEEDS</b>
PFHxS	10.1	10.0	1.01	<b>EXCEEDS</b>
PFPeA	6.8	-	-	No federal limit
PFHxA	6.1	-	-	No federal limit
PFBS	5.3	-	-	No federal limit

### What This Means

This water system serves 114,468 residents in Kennewick. EPA testing detected 29 PFAS compounds, 3 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

### What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans