

## QUISTORFF

Tacoma, WA | PWSID: WA5370550 | Population served: 1,113

Based on EPA UCMR 5 testing data (2023-2025) | Report generated May 25, 2026



### PFHxS exceeds the federal limit at 4.40x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

### Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFHxS	44.0	10.0	4.40	<b>EXCEEDS</b>
PFOS	11.5	4.0	2.88	<b>EXCEEDS</b>
PFBS	33.5	-	-	No federal limit
PFPeS	19.5	-	-	No federal limit
PFPeA	16.5	-	-	No federal limit
PFHxA	16.5	-	-	No federal limit
PFBA	6.9	-	-	No federal limit

### What This Means

This water system serves 1,113 residents in Tacoma. EPA testing detected 29 PFAS compounds, 2 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

### What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans