# Water Quality Report Card

CheckYourWater.org

## SPANAWAY WATER COMPANY

Spanaway, WA | PWSID: WA5382850 | Population served: 31,908

Based on EPA UCMR 5 testing data (2023-2025) | Report generated November 25, 2026

**D**

### PFOA exceeds the federal limit at 1.55x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

## Findings

| Compound | Detected (ppt) | EPA Limit (ppt) | Ratio | Status |
|---|---|---|---|---|
| PFOA | 6.2 | 4.0 | 1.55 | **EXCEEDS** |
| PFOS | 5.9 | 4.0 | 1.47 | **EXCEEDS** |
| PFHxS | 3.5 | 10.0 | 0.35 | Below limit |
| PFBS | 4.9 | - | - | No federal limit |
| PFPeA | 4.7 | - | - | No federal limit |
| PFHxA | 4.7 | - | - | No federal limit |

## What This Means

This water system serves 31,908 residents in Spanaway. EPA testing detected 29 PFAS compounds, 2 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

## What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans



This report is provided for informational purposes. It is not a substitute for professional water quality analysis.