

## WILLIAMSTOWN WATER DEPT

WILLIAMSTOWN, WV | PWSID: WV3305412 | Population served: 3,469

Based on EPA UCMR 5 testing data (2023-2025) | Report generated April 8, 2026



### PFOA severely exceeds the federal limit at 6.53x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

### Findings

| Compound | Detected (ppt) | EPA Limit (ppt) | Ratio | Status           |
|----------|----------------|-----------------|-------|------------------|
| PFOA     | 26.1           | 4.0             | 6.53  | <b>EXCEEDS</b>   |
| PFHxS    | 20.0           | 10.0            | 2.00  | <b>EXCEEDS</b>   |
| PFBS     | 8.4            | -               | -     | No federal limit |
| PFHxA    | 7.2            | -               | -     | No federal limit |
| PFBA     | 6.0            | -               | -     | No federal limit |
| PFPeA    | 3.5            | -               | -     | No federal limit |
| PFHpA    | 3.5            | -               | -     | No federal limit |

### What This Means

This water system serves 3,469 residents in WILLIAMSTOWN. EPA testing detected 29 PFAS compounds, 2 of which exceed federal drinking water limits. Residents served by this system should consider installing an NSF 53 or NSF 58 certified water filter.

### What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans