Water Quality Report Card

CheckYourWater.org

Hastings, MN

Hastings, MN | PWSID: MN1190012 | Population served: 23,222

Based on EPA UCMR 5 testing data (2023-2025) | Report generated November 25, 2026

D

PFOA exceeds the federal limit at 2.95x the EPA maximum

The EPA set enforceable limits for six PFAS compounds in April 2024. Grade reflects the worst single compound result.

Findings

Compound	Detected (ppt)	EPA Limit (ppt)	Ratio	Status
PFOA	11.8	4.0	2.95	**EXCEEDS**
PFOS	4.5	4.0	1.14	**EXCEEDS**
PFHxS	3.3	10.0	0.33	Below limit
PFBA	155.9	-	-	No federal limit
PFBS	3.3	-	-	No federal limit
PFHxA	4.9	-	-	No federal limit
PFPeA	10.8	-	-	No federal limit

What This Means

Summary Hastings's municipal water supply has earned a D grade, meaning residents are being served water with PFAS contamination that exceeds federal health limits. Two compounds surpass EPA thresholds: PFOA was detected at 11. 8 parts per trillion, nearly three times the federal limit of 4 parts per trillion, and PFOS came in at 4.

What You Can Do

- Request your utility's full Consumer Confidence Report (CCR) for additional water quality data
- Consider an NSF 53 (pitcher) or NSF 58 (reverse osmosis) certified filter if PFAS were detected
- Attend your local water board or city council meeting to ask about treatment plans

This report is provided for informational purposes. It is not a substitute for professional water quality analysis.